

EN - Safety instructions - Installation instructions

Alpha recessed

1- Installation and commissioning may only be carried out by authorized specialists. Electrical components must be connected by qualified electrician.

2- BEWARE! Make sure the luminaries are always disconnected from the mains supply during wiring, installation and maintenance work. Before starting the installation, make sure the power is switched off.

3- This fixture is suitable for indoor wall/ceiling or for cove lighting use. The luminary is exclusively used for lighting and is to be installed in accordance with the national regulations. Any other use or installation is regarded as "non according to instructions".

4- The luminary with F mark are suitable for installation on normally flammable surfaces (for example wood and wood-based materials of more than 2 mm thickness).

5- Do not put the luminary on surfaces that are wet, recently painted or on electrical connections.

6- Always be sure to keep a minimum spacing of more than 0.5m (50cm) between the luminary and the illuminated surface.

7- Do not cover the luminaire. Do not hang anything from the luminaire.

8- Ceiling and wall installation:

Take off the luminaires acrylic diffuser.

Check the code and cut the plasterboard ceiling according to dimensions of the table below.

Connect the power cable supply into the fitting at the terminal block according to the marks

Pass the fitting into the ceiling hole.

Place the mounting component tied.


Place the lamps.

Place the acrylic diffuser cover back.

Code	8600	8600DIM	8602	8604
Cut/Out Dimensions mm	595 X 595	595 X 595	595 X 595	595 X 595
Code	8605	8601	8601DIM	8603
Cut/Out Dimensions mm	595 X 595	580 X 580	580 X 580	580 X 580
Code	8606	8607	8630	8630DIM
Cut/Out Dimensions mm	580 X 580	580 X 580	205 X 1180	205 X 1180
Code	8631	8635	8636	8637/DIM
Cut/Out Dimensions mm	205 X 1180	205 X 1480	205 X 1480	205 X 1480

9- Cleaning is limited to the external parts of the luminary. Do not clean under high pressure.

Protection class I. The ground cable (green/yellow) must be connected. If there is not a mains supply with a protective ground wire available, the product must not be connected / used there



KEEP THESE INSTRUCTIONS FOR FURTHER REFERENCE.

